FPH Series

FPH 115

FLAME PROOF HOOTER



Mechanical Data

Material : Cast Aluminium LM 6
Weight : 5 Kg (approx.)

IP Protection : IP 65 as per IS 13947 / 93(IEC 60529 / 1989)

Finish : Anti corrosive Epoxy - Powder Coated

Cable Entry : 2 x 3/4" ET
Gasket : Neoprene
Hardware : Stainless Steel

Terminals : 4 x 2.5 sq. mm (standard)

: 6 x 2.5 sq. Mm (for looping)

Electrical Data

Voltage : 24 V DC or 110 V / 230 V AC - 50 Hz Out put Current : 600 mA Peak. Galvanically Isolated

Power rating : 18 Watts Sound Output : 106 db

900 Hz $\,$ On $\,$ OFF alternatively at 1C/S $\,$


Earthing : External : 2 Nos. - M6

Internal: 1 No. - M5

Baliga

Description

Explosion proof cum Intrinsically safe hooter. In the main chamber Intrinsically safe circuit is housed and it is duly wired up to terminal chamber through sealed bushes. The horn unit is placed on the main chamber cover and the output signals are taken through sealed coils. Neoprene 'O' rings are provided for the weather proof protection.



Type of protection Flame Proof - Exd T6 IP 65

Area Classification Zone 1 & 2

Gas groups Group I, II A, II B, II C


Apparatus Standard IS - 2148/2004(IEC 60079-1/2001)

CMRI Certificate No. CMRI / TC / S / H388

Approvals CCE,BIS

Salient Features

Output is galvanically isolated



केन्द्रीय खनन एवं ईंधन अनुसंधान संस्थान

(वैज्ञानिक तथा औद्योगिक अनुसंधान परिषद) बरवा रोड, धनबाद — 826015, झारखण्ड (भारत)





CENTRAL INSTITUTE OF MINING AND FUEL RESEARCH

Formerly: Central Mining Research Institute
(COUNCIL OF SCIENTIFIC & INDUSTRIAL RESEARCH)

BARWA ROAD, DHANBAD - 826015, JHARKHAND (INDIA)

REGISTERED POST/COURIER SERVICE

No. CIMFR/TC/SR/#/355 I.D. No. 952/07 Dated: OS July,2008 CODE NO. FLP/204S/08

To

M/S. BALIGA LIGHTING EQUIPMENTS PVT. LTD., 389, MEDAVAKKAM ROAD, KOVILAMBAKKAM, CHENNAI-600 117

<u>Sub</u>: Supplementary Testing for **REVALIDATION** as per IS: 2148-2004 (IEC 60079-1/2001) of your **Flameproof cum Weatherproof (IP-65) Multitone Audio Visual Alarm, designated by Cat. No. FPHF-117** in cast aluminium alloy LM-6 construction for use in Zone 1 & 2 and Gas Groups: IIA & IIB atmosphere only.

- Report on (REVALIDATION)

Your Ref. Appl. No.: CMRI/6/274/IIB

Dated: 21/12/2007

Dear Sir,

Please find enclosed the **Supplementary Test Report** for **REVALIDATION** of the above sample as per IS: 2148-2004.

The above apparatus was earlier certified as per IS: 2148-1981 vide CMRI Test Report No. CMRI/TC/P/H1187, Dated: 15/10/2001.

Charges of Rs. 14,754/- (Rupees Fourteen thousand Seven hundred Fifty Four only) including applicable service charges involved towards the testing/issuing the schedule have been adjusted against the advance deposit made by you.

Kindly arrange to collect the sample within 90 days from the date of receipt of this letter failing which CIMFR would dispose off the sample by public auction without any further NOTICE to you.

Kindly acknowledge receipt.

Thanking you,

Yours faithfully,

Encl.: As above

Suppl. Report for Revalidation in Triplicate

Copy to: 1. Head, Flame & Explosion Lab.

2. Bill Section.

(G. M. PRASAD)
HEAD OF THE DEPARTMENT
TESTING CELL

Page 1 of 7

फोन - निदेशक Director Ph.: 0091 326 2202326/2203043 पी० ए० एक्स PAX

फैक्स FAX

Ph.: 0091 326 2296027/2296028/2296029/2296010/2296013

Ph.: 0091 326 2296019/2202429/2204339/2203150

e-mail : dcmrips@yahoo.co.in,dcmri@csir.res.in. Website : www.cmriindia.nic.in कार्यालय के दिन : सोमवार से शुक्रवार तक **Working days : Monday to Friday**